

## TwinCAT system properties on PC with TwinCAT

In Visual Basic after adding TwinCATComm to form

TwinCATComm1 MfgControl.AdvancedHMI.TwinC	
(ApplicationSettings)	
(Name)	<b>TwinCATComm1</b>
aTargetAMSNetID	<b>172.16.20.13.1.1</b>
DisableSubscriptions	<b>False</b>
GenerateMember	<b>True</b>
Modifiers	<b>Friend</b>
Password	<b>1</b>
SynchronizingObject	<b>MainForm</b>
TargetAMSPort	<b>801</b>
TargetIPAddress	<b>172.16.20.13</b>
UserName	<b>Administrator</b>
UseStaticRoute	<b>False</b>

**TwinCAT System Properties**

General System AMS Router PLC Registration

Local Computer

AMS Net Id: **172.16.20.13.1.1**

Remote Computers

- CX\_08BD64
- CX\_08C774
- CX\_0AD4C4
- CX\_0C827E
- CX-09D0EE
- MCCXP-52
- MCCXP-53

Add Remove Properties

OK Cancel Apply

IP Address of the PC with TwinCAT

User name with admin rights on PC with TwinCAT

Password for the admin user account on the PC with TwinCAT